

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3774-1473:100 Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** OSI Security Devices, 1580 Jayken Way, Chula Vista, CA 91911-4644  
Contact: Allan Outzs (619) 628-1000 Fax (619) 628-1001\*

**DESIGN:** Model OM250TL electrically controlled single-point lock or latch, followed by suffix -L, -K, -KB, -KBC, -M, -MR, -MD, -MDR or -RMS. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as electric lock for use with 20-minutes fire rated doors not exceeding 4' wide and 8' high. Authority having jurisdiction should be consulted prior to installation. For indoor use only.

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager